

## **Building Safety Report (PART-II)**

**NAME OF SCHOOL:- SRKS ADARSH SENIOR SECONDARY SCHOOL, BOHA**  
**(District- MANSA)**

As per report of Sh. Vijay Kumar Junior Engineer on his visually inspection on dated 22.12.2022 the above mentioned school seems visually safe subject to the following observations and conditions.

1. The Parameters to check the stability and safety of building such as structural Design, Architectural Drawings, Bearing capacity, Foundation details, Structural drawings, Technical Specifications, Test reports of Material used and Quality control reports are not available
2. In case any addition, alteration, expansion and modification to this building are required/to be done, regarding this, inspection of undersigned may be arranged and obtained a certification after the completion from the undersigned.
3. In the case of building is affected by flood or if there is any settlement of walls foundation of roof etc. immediately inspection of the undersigned arranged to check the stability and safety of the building.
4. A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
5. A separate certificate regarding Electrical works should be obtained from the competent Authority.
6. The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
7. This report is for the covered area of the school building 49638.52 sft which is submitted by the owner of the school building as per drawing.
8. The building of the school is constructed as brick masonry.
9. This report is not valid for legal purpose.
10. That the fee charges for the year 2022-2023 Rs.Ten Thousand only vide GR. No. 2843503 Dated 08.12.2022
11. Fire safety Certificate is valid till 10.08.2023 and School will be responsible to get renewed fire safety Certificate within time limit.

As per visually inspection as reported by the concerned Junior Engineer the above building may be used for normal use up to 31.03.2023 Subject to the above conditions.

**Junior Engineer**

  
**Executive Engineer**  
**Provl. Div. PWD B&R Dr.**  
**Mansa** 